



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer,Howrah**  
**West Bengal Fire & Emergency Services**  
**430, G.T. Road, Howrah(N), Pin :- 711101**

Memo no.:FSR/0125186231300654

Date: 30-10-2023

**From:**  
**Divisional Fire Officer,Howrah**  
**West Bengal Fire & Emergency Services**

**To: JAGADISH CHANDRABASU SIKSHAK SIKSHAN MAHAVIDYALAYA**  
**DAG NO-59,60,61,65,66,KHT. NO.-274,301, UNDER JHAPARDHA GRAM PANCHAYET,108,626, J.L. NO.-2, MOUZA-CHAK MAHISJOL,DIST.- HOWRAH,**

**Sub: Fire Safety Certificate for an existing construction of G+2 Storied building under group of Educational in the name & style as " Jagadish Chandra Basu Sikshak Sikshan Mahavidhyalaya " at the premises Dag No-59,60,61, 65,66, L. R. Khatian No-274, 301, 108,626, under Jhapardha Gram Panchayat , J. L. No-02, Mouza- Chakmahisjol, PS- Domjur, Dist-Howrah, Pin-711405.**

This is in reference to your application no. 0125189231300247 dated 17-10-2023 regarding the Fire Safety Certificate for an existing construction of G+2 Storied building under group of Educational in the name & style as " Jagadish Chandra Basu Sikshak Sikshan Mahavidhyalaya " at the premises Dag No-59,60,61, 65,66, L. R. Khatian No-274, 301, 108,626, under Jhapardha Gram Panchayat , J. L. No-02, Mouza- Chakmahisjol, PS- Domjur, Dist-Howrah, Pin-711405.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free from any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way .
2. The internal finish decoration of the building shall be made low flame spread conforming I.S. specification .
3. To eliminate risk of fire hazard , good house keeping both for inside and out side the building shall be strictly maintained.
4. A fire control room including a closed circuit TV system will have to be maintained observe all floor of the building .
5. " No Smoking " board should be displayed .
6. The employees and security staff shall be conversant with installed Fire Fighting equipment's and to operate in the event of Fire and testing.
7. Mock fire practice and evacuation drill shall be performed periodically with all employees of the building .
8. First Aid Fire fighting system shall be provided as per I.S. specification.
9. A crew of trained fireman under an experienced officer shall be maintained round the clock for safety of the building .
10. The notice of fire fighting and evacuation from the building shall be prepared and displayed at all venerable places of

the building.

11. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register .

12. This Fire Safety Certificate is valid for three ( 03 ) years and has to be renewed after three years from the date of issue of this certificate as per notification Govt. of West Bengal vide Notification No- 629-L, Dated- 17/04/2018 , Certifying about the satisfactory services , Performance of all life and fire safety arrangement of the educational building.

Signature valid

Digitally signed by RANJAN  
KUMAR GHOSH  
Date: 2023.10.20 17:04:56 IST

Divisional Fire Officer,Howrah  
West Bengal Fire & Emergency Services

Memo No.:FSR/0125186231300247